

Title	Heat transfer of high pressure and high temperature water in forced convection
Sub Title	
Author	狼, 公平(Okami, Kohei)
Publisher	慶應義塾大学藤原記念工学部
Publication year	1965
Jtitle	Proceedings of the Fujihara Memorial Faculty of Engineering Keio University (慶應義塾大学藤原記念工学部研究報告). Vol.18, No.71 (1965.) ,p.92(28)- 92(28)
JaLC DOI	
Abstract	
Notes	Summaries of Doctor and Master Theses Master of Engineering, 1965 Mechanical Engineering
Genre	Departmental Bulletin Paper
URL	https://koara.lib.keio.ac.jp/xoonips/modules/xoonips/detail.php?koara_id=KO50001004-00180071-0028

慶應義塾大学学術情報リポジトリ(KOARA)に掲載されているコンテンツの著作権は、それぞれの著作者、学会または出版社/発行者に帰属し、その権利は著作権法によって保護されています。引用にあたっては、著作権法を遵守してご利用ください。

The copyrights of content available on the KeiO Associated Repository of Academic resources (KOARA) belong to the respective authors, academic societies, or publishers/issuers, and these rights are protected by the Japanese Copyright Act. When quoting the content, please follow the Japanese copyright act.

Heat Transfer of High Pressure and High Temperature Water in Forced Convection

Kohei OKAMI*

Nowadays power plants require increasingly higher pressure and higher temperature steam to raise their efficiency. It is expected that generally steam in the supercritical region will be used more and more.

The available informations about the heat transfer coefficient of steam in the supercritical region is limited owing to the large and complex change of the physical properties of steam in that region. So many researchers are trying to study the heat coefficient of supercritical steam experimentally. But at present no clear results have been obtained. The author tried to get exploring data with newly built apparatus.

First the author designed and constructed the new apparatus, and then tried following experiment to confirm its characteristics at the region of moderate pressures and temperatures. In the past, heat transfer experiments have been performed under high heat flux to be applied to power plants, and in those studies the formula $N_u=f(R_e, P_r)$ has been used. The author tried to find heat transfer coefficient under lower heat flux. For the case of low heat flux, the author proposed new formula, $N_u=f(R_e, P_r, K)$.

In this case K means dimensionless number which shows how many heat flux is given to the fluid.

*狼 公 平