Title	A study of surge-tank stability condition at a hydraulic power station
Sub Title	
Author	今村, 義明(Imamura, Yoshiaki)
Publisher	慶応義塾大学藤原記念工学部
Publication year	1967
Jtitle	Proceedings of the Fujihara Memorial Faculty of Engineering Keio University (慶応義塾大学藤原記念工学部研究報告). Vol.20, No.81 (1967.),p.182(6)- 182(6)
JaLC DOI	
Abstract	
Notes	Summaries of Doctor and Master Theses
Genre	Departmental Bulletin Paper
URL	https://koara.lib.keio.ac.jp/xoonips/modules/xoonips/detail.php?koara_id=KO50001004-00200081- 0006

慶應義塾大学学術情報リポジトリ(KOARA)に掲載されているコンテンツの著作権は、それぞれの著作者、学会または出版社/発行者に帰属し、その権利は著作権法によって 保護されています。引用にあたっては、著作権法を遵守してご利用ください。

The copyrights of content available on the KeiO Associated Repository of Academic resources (KOARA) belong to the respective authors, academic societies, or publishers/issuers, and these rights are protected by the Japanese Copyright Act. When quoting the content, please follow the Japanese copyright act.

A Study of Surge-Tank Stability Condition at a Hydraulic Power Station

Yoshiaki IMAMURA*

In this thesis, a stability condition at a hydraulic power station is treated. Thoma's theory gives the stability condition under the assumption that the hydraulic power to the turbine is constant and the power station is isolated from other stations, while other theories give the stability condition under the assumption that the power station is not isolated and interconnected with other station. In this theory, the only effect of the water level displacement of one station is considered and that of others are neglected. The author gives such a stability condition that contains the effect of the water level displacement of other stations. The result of calculation shows that the effect of the water level displacement of other stations is fairly large. Particularly in the case that the periods of the oscillation of some power stations are nearly equal, the water level sometimes becomes unstable, even if Thoma's theory is fulfilled. So, the period of the oscillation from that of other stations should be separated when the power stations are interconnected each other. Generally, the governor time lag is neglected in the theoretical analysis for the stability conditions, because it is shorter than the period of the oscillation of the water level displacement, but in this thesis, stability condition is discussed without neglecting this effect.

*今 村 義 明