| Title            | Discharge phenomena at breaking contacts of inductive circuits   |
|------------------|--|
| Sub Title        |  |
| Author           | 高橋, 篤夫(Takahashi, Atsuo)   |
| Publisher        | 慶応義塾大学藤原記念工学部  |
| Publication year | 1967   |
| Jtitle           | Proceedings of the Fujihara Memorial Faculty of Engineering Keio<br>University (慶応義塾大学藤原記念工学部研究報告). Vol.20, No.81 (1967.),p.238(62)- 238(62) |
| JaLC DOI         |  |
| Abstract         |  |
| Notes            | Summaries of Doctor and Master Theses  |
| Genre            | Departmental Bulletin Paper  |
| URL              | https://koara.lib.keio.ac.jp/xoonips/modules/xoonips/detail.php?koara_id=KO50001004-00200081-<br>0062  |

慶應義塾大学学術情報リポジトリ(KOARA)に掲載されているコンテンツの著作権は、それぞれの著作者、学会または出版社/発行者に帰属し、その権利は著作権法によって 保護されています。引用にあたっては、著作権法を遵守してご利用ください。

The copyrights of content available on the KeiO Associated Repository of Academic resources (KOARA) belong to the respective authors, academic societies, or publishers/issuers, and these rights are protected by the Japanese Copyright Act. When quoting the content, please follow the Japanese copyright act.

## Discharge Phenomena at Breaking Contacts of Inductive Circuits

## Atsuo TAKAHASHI\*

The boundary domain between steady arc and the interrupted arc at the breaking contacts of inductive circuits is investigated by varying contact current, circuit capacitance and local inductance. Moreover, the characteristics of interrupted arc initiated below the minimum sparking voltage, are also studied experimentally.

The main results are as follows,

(1) The boundary between steady arc and interrupted arc is determined by the charging current of the main circuit capacitance.

(2) Arc extinction current is not constant, and is dependent upon the contact current and local inductance. This seemes to be attributed to cleaning action of the electrode surface by the arc.

(3) Atall's theory concerning interrupted arc is confirmed, when the arc initiation voltage is below the minimum sparking voltage.

(4) Interrupted arc voltage is not constant, whereas steady arc voltage is substantially constant. This seems to be connected with the characteristics of high frequency large current arc.

(5) The first arc initiation voltage in the region of interrupted arc, depends upon the contact current. This shows the first gap length made by breakdown of bridge is a linear function of the contact current.

## \*高橋篤夫